



SPECIALIST FIRE SOLUTIONS LTD

Unit 1 Chalford Industrial Estate
Chalford
Stroud
GL6 8NT
Telephone: 01453 731006
Fax: 01453 731044
sales@fireproof.co.uk
www.fireproof.co.uk

TO UP GRADE 40mm AND ABOVE FLAT PANEL DOORS USING ENVIROGRAF ES/MP900 INTUMESCENT FIRE CARD & HW INTUMESCENT COATING SYSTEM

ACHIEVING FD30/S - 30 MINUTES FIRE INTEGRITY TO BS 476 PART 22: 1987

- Prepare panels & beading only (room side) by rubbing down lightly with fine sand paper to achieve a key and to remove any flaking paint
- Fix Envirograf ES/MP900 intumescent fire card to panels on risk face (room side) using Envirograf IA intumescent adhesive
- Apply to the beading only on risk face (room side) 2 x coats HW01/F white intumescent coating and 1 x coat HW04/S white satin protective coating
- Fit Envirograf IS14/S (10mm x 4mm) white fire & smoke seals to door edges
- **Or**
- Envirograf ES/SDS white surface mounted fire & smoke seals to door frame
- Fit 3 No 100mm stainless steel hinges grade 13 CE stamped
- Fit HP32/Kit intumescent hinge protection behind all hinges
- Fit suitable fire rated overhead door closer ie Briton 2003V

**SPECIFIERS, DISTRIBUTORS AND INSTALLERS OF PASSIVE INTUMESCENT FIRE PREVENTION PRODUCTS
SUPPLIERS AND INSTALLERS OF WIRED AND WIRELESS FIRE ALARM SYSTEMS**

Specialist Fire Solutions Limited
Registered in England and Wales No: 07069807
VAT Registration Number: 980 3888 76
Registered Office Address:
Camburgh House 27 New Dover Road Canterbury CT1 3DN
Directors: Martyn G Young, Jacqueline AR Young

Working in partnership with



Nationwide Association
of Passive Fire
Installers & Specifiers

